



Gardner Architects

12/15/2009

January 5, 2010

Renovations to:
7991 Columbus Pike
Lewis Center, Ohio 43035

ADDENDUM #6:

This Addendum, hereby modifies, supplements and amends the original Specifications and Drawings for all material, labor and equipment of every nature necessary for the execution of the entire work Renovations to: 7991 Columbus Pike, Lewis Center, Ohio 43035, as prepared by Gardner Architects, dated in the Title Block: 12.1.2009. Wherein this Addendum varies or is in conflict with the Specifications or Drawings, the requirements of this Addendum shall govern, in all other particulars the requirements of the original Specifications and Drawings, dated December 1, 2009, shall govern.

Specification Items

Item #1: DIVISION 23

Section 230923 Direct Digital Temperature Control System

Paragraph 2.02 L. 9.

Change the paragraph to read as follows:

The graphic interface shall include a graphic display showing total accumulated energy consumption in kwh units and a resettable (provide graphic reset button and display date and time of last reset) energy consumption accumulation in kwh. The E.C. shall provide conduit and wire from panel to panel for use by DDC system. T.C. shall provide pulse meter and wiring to the DDC system. Provide input point and programming to interpret pulse data and display house panel energy consumption (both total accumulation and resettable interval) on BAS computer. Wire pulse data circuit complete and verify correct values of energy consumption are displayed.

Addenda Items

Item #2: ADDENDUM #1, ITEM #40

This item does not pertain to Sheet E1.1.1. Delete this reference and replace with Sheet E1.2

END OF ADDENDUM #6